

Annexure C

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No. 540

Dated: 23/5/2025

It is certified that an inspection team headed by Vinod Kumar

(Name of Officers with designation) from Water Testing Laboratory PHED Fatehabad

inspected the Maharaja Aggarwain Sr. Sec. School, Tohana

(Name & Address of the school) on 21/05/2025 (date of inspection) and on the basis of

Water Test Report (Attached) bearing no. 533 dated 23/05/2025

of Physical & Chemical Test (PHED Lab) certified that


the Maharaja Aggarwain Sr. Sec. School (Name of school) has safe drinking water

facilities for the students and members of staff of the institution. School is also maintains the

hygienic sanitation condition in the school building & the campus as per norms prescribed by the

Central/ State/ U.T. Govt.

This certificate is valid till date 21/05/2026



Chemist
Public Health Engineering
Water Testing Laboratory

Signature with Seal: Fatehabad-125050

Name: Kanchar Bishnoi

Designation: Chemist

Name & Address of the Office / Department: Fatehabad

To

Maharaja Aggarwain
Sr. Sec. School, Tohana
(Name & Address of the Institution)

Note: The certificate is to be issued by authorized officer / PHED Lab / local bodies



OFFICE OF THE CHEMIST
WATER TESTING LABORATORY PUBLIC HEALTH
ENGINEERING DEPARTMENT, FATEHABAD

E-mail:-chemist.fatehabad@phedharyana.gov.in, chemistftbad7@gmail.com



Chemical Examination Report of Water Sample

Test Report No :- FTBD/00639/5/2025	Issue Date :- 21-05-2025
Issue To:- Maharaja Aggarsain Sr. Sec. School, Mirch Mandi Road, Tohana	Location :- W/s Maharaja Aggarsain Sr. Sec. School
Your Reference No - 2209 Date 16-05-2025	Collected By :- Krishan Kumar (Client)
Sample Type - Drinking Water	Sample Received Date & Time :- 20-05-2025
Lab Job Order No.- 2350502	Sample Received Date & Time :- 20-05-2025
Date(s) of Analysis :- 20-05-2025 to 21-05-2025	Sample Quantity :- 1 Ltr

Environmental Condition :- Temp. $25 \pm 2^\circ\text{C}$ Humidity $55 \pm 15\%$

S. No.	Parameter	Protocol Used	Results	IS: 10500:2012 (Second Revision) RA- 2018		Unit
				Desirable limit	Max. Permissible limit (in absence better alternate source)	
12	Iron	APHA 3500-Fe B, 2017 23rd Edition 2017	0.04	1.0	1.0	mg/L
13	Sulphate	APHA 4500 E 23rd Edition 2017	45	200	400	mg/L
14	Fluoride (as F)	APHA 4500 -F D, C2017 23rd Edition 2017	0.28	1.0	1.5	mg/L
15	Nitrate (as NO ₃)	APHA 4500-NO ₃ -D:2017 23rd Edition 2017	2.85	45	No relaxation	mg/L

Remarks:- The Parameter Tested at Sr.No 12-15 as per requirement of IS:10500:2012 second Revision (RA2018).

Note

s:

- The results given above are related to the sample as received and tested in PHED Lab, Fatehabad Reliability of sample lies with the sender.
- The test report can't be regenerated/re-produced in whole or in part without written permission of Laboratory.
- The test report can't be used for any publicity or any legal purpose.
- The test samples meant for chemical analysis will be disposed off after 15 days from the date of issue of test report unless until specifically requested by the customer for retaining over a longer period.

Vinod

Sample analyzed by

(Kanchan Bishnoi)

Authorized Signatory/Chemist
 PHED Water Testing Laboratory, Fatehabad



OFFICE OF THE CHEMIST
WATER TESTING LABORATORY PUBLIC HEALTH
ENGINEERING DEPARTMENT, FATEHABAD
 E-mail:-chemist.fatehabad@phedharyana.gov.in,



Chemical Examination Report of Water Sample

Test Report No : -FTBD/00639/5/2025			Issue Date :- 21-05-2025		TC-12220	
Issue To:- Maharaja Aggarsain Sr. Sec. School, Mirch Mandi Road, Tohana			Location :- W/s Maharaja Aggarsain Sr. Sec. School			
Your Reference No - 2209 Date 16-05-2025			Collected By :- Krishan Kumar (Client)			
Sample Type - Drinking Water			Sample Received Date & Time :- 20-05-2025			
Lab Job Order No.- 2350502			Sample Received Date & Time :- 20-05-2025			
Date(s) of Analysis :- 20-05-2025 to 21-05-2025			Sample Quantity :- 1 Ltr			
Environmental Condition :- Temp. $25 \pm 2^\circ\text{C}$ Humidity $55 \pm 15\%$						
Results						
S. No.	Parameter	Protocol Used	Results	IS: 10500:2012 (Second Revision) RA- 2018		Unit
				Desirable limit	Max. Permissible limit (in absence better alternate source)	
1	Total Dissolved Solids @ $180^\circ\text{C} \pm 2^\circ\text{C}$	APHA 24th Edition - 2540 C	450	600	2000	mg/L
2	Total Hardness (as CaCO_3)	APHA 24th Edition-2340-Hardness Method C (EDTA Method):	290	200	600	mg/L
3	Calcium (as Ca)	APHA 24th Edition 3500-C	76.152	75	200	mg/L
4	Magnesium (as Mg)	APHA 24th Edition 3500-Mg Method B (Calculation)	24.3	30	100	mg/L
5	Total Alkalinity (as CaCO_3)	APHA 24th Edition-2320-Method B (Titration)	160	200	600	mg/L
6	Chloride (as Cl)	APHA 24th Edition 4500-Cl Method B(Argentometric Method) 2017	99.9	250	1000	mg/L
7	pH @ 25°C	APHA 24th Edition 4500-H+Method B	8.01	6.5 -8.5	No relaxation	-
8	Turbidity	APHA 24th Edition - 2130	0.96	1	5	NTU
9	Taste	IS 3025 (PART-7)	Agreeable	Agreeable	Agreeable	-
10	Odour	IS 3025 (PART-5)	Agreeable	Agreeable	Agreeable	-
11	Color	APHA 24th Edition 2120 B	<5	5 Hazen	15 Hazan Units	Hazen Units

Remarks:- The Parameter Tested at Sr.No 1-11 as per requirement of IS:10500:2012 second Revision (RA2018).

Notes:

- The results given above are related to the sample as received and tested in PHED Lab, Fatehabad Reliability of sample lies with the sender.
- The test report can't be regenerated/re-produced in whole or in part without written permission of Laboratory.
- The test report can't be used for any publicity or any legal purpose.
- The test samples meant for chemical analysis will be disposed off after 15 days from the date of issue of test report unless until specifically requested by the customer for retaining over a longer period.

Sample analyzed by

(Kanchan Bishnoi)
 Authorized Signatory/Chemist
 PHED Water Testing Laboratory, Fatehabad

PUBLIC HEALTH ENGINEERING DEPARTMENT
DISTRICT WATER TESTING LABORATORY ,FATEHABAD

Website :- <https://phedharyana.gov.in/>

Memo No:- 533

Date:- 23/05/2025

Subject : Bacteriological Examination Report of Water Sample

Sample ID:	FTBD/00666/5/2025	Sample Details	Date & Time
Sample Classification:	Private	Collected By	Vinod Kumar,9416751289
Sender:	Maharaja Aggarsain Sr. Sec. School	Collection Date	21/05/2025 at 12:46
Location :-	, MIRCH MANDI ROAD TOHANA	Received at lab	21/05/2025 at 14:48
Latitude :-	75.901350	Tested at Lab	23/05/2025
Longitude :-	29.713695		

Test Result (As Per BIS 10500 :2012)


S.No.	Tested Parameter	Result	Requirement (Acceptable Limit)	Protocol Used
1	Total Coliform per 100 ml	0	Shall not be detectable in any 100 ml sample	IS 15185:2016/APHA 9223B-2023/APHA 9221C-2023

Remarks :-

- * The Results Given above are related to the sample as received and tested in FATEHABAD lab.
- * The test report can't be regenerated in whole or part there of without written permission of Competent Authority.
- * The test report can't be used for any publicity or any legal purpose.
- * Reliability of water sample sample lies with sender/collector of water sample.
- * To check the sample report online Scan the QR Code below.

Water Sample has been found "**CONFORMING**" to Limits set in BIS10500:2012 for the tested parameters.
Based on the tested parameters,the water sample is found "**POTABLE**"




KANCHAN BISHNOI,CHEMIST
PUBLIC HEALTH ENGINEERING DEPARTMENT
DISTRICT WATER TESTING
LABORATORY,FATEHABAD
email:-chemist.ftbad@phedharyana.gov.in

-----End of Report-----.